BRE Global

Notified Body No. 0832

BRE Global Limited Bucknalls Lane, Garston, Watford, Hertfordshire, UK, WD25 9XX Telephone: +44 (0)1923 664100 Fax: +44 (0)1923 664603 Email: <u>enquiries@breglobal.com</u> Web: <u>www.breglobal.com</u>

Certificate of constancy of performance,

0832-CPR-F1577

In compliance with Regulation 305/2011/EU of the European Parliament and of the council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

WLS/BOP Wireless Battery Powered Output Module

(For full product details and conditions of use refer to appendix)

Produced by or for

Protec Fire Detection Plc

Protec House Churchill Way Nelson Lancashire BB9 6RT United Kingdom

and produced in the manufacturing plant(s)

Argus Security Srl

Via del Canneto 14 Valle delle Noghere 34015 Trieste Italy

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 54-18:2005 Input/output devices EN 54-25:2008 Components using radio links

under system 1 are applied and that

the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 17 February 2017 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

Walligar.

Peter Halligan, Certification Manager On behalf of BRE Global Limited Date of issue: 17 February 2017 Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions. To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.

BRE Global

Notified Body No. 0832

BRE Global Limited Bucknalls Lane, Garston, Watford, Hertfordshire, UK, WD25 9XX Telephone: +44 (0)1923 664100 Fax: +44 (0)1923 664603 Email: <u>enquiries@breglobal.com</u> Web: <u>www.breglobal.com</u>

Appendix to Certificate of constancy of performance 0832-CPR- F1577

Note:

- 1. The device must be used with the following batteries only:
- CR123A (3Vdc) Main Battery
- CR123A (3Vdc) Secondary Battery

Walligan

Peter Halligan, Certification Manager On behalf of BRE Global Limited Date of issue: 17 February 2017 Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions. To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email <u>enquiries@breglobal.com</u>.